

## **Proposal for amendments to Regulation No. 67 (Equipment for liquefied petroleum gas (LPG))**

The modifications to the proposal ECE/TRANS/WP.29/GRSG/2012/7 are marked in blue.

*Paragraphs 6.15.2.1. and 6.15.2.2., amend to read:*

- "6.15.2.1. The electrical connections inside the boot and passengers compartment shall comply with insulation class IP 40 according to IEC **Standard 60529-1976**.
- 6.15.2.2. All other electrical connections shall comply with insulation class IP 54 according to IEC **Standard 60529**.**[ISO 20653-2006 (currently being revised)]** "

*Paragraph 6.15.13.1.1., amend to read:*

"6.15.13.1.1. In case the ..... insulation class IP 40 according to IEC **Standard 60529**."

*Paragraph 17.11.4., amend to read:*

"17.11.4. Electrical cables shall ..... with insulation class IP 40 according to IEC **Standard 60529**. All other electrical connections shall comply with insulation class IP 54 according to IEC **Standard 60529**."

*Annex 10,*

*Paragraph 2.1.2.3.1., amend to read (~~including the insertion of a new footnote 1/~~):*

"2.1.2.3.1. The bend test shall be carried out in accordance with standards ISO 7438:~~2003~~ **2005 1/** and ~~ISO 7799:2000~~ and ISO 7799:1985 and ~~Euronorm EN 910~~ **ISO 5173:2010** for welded parts. The bend tests shall be carried out on the inner surface in tension and the outer surface in tension.

---

~~1/ ISO 4009, referred to in this standard, need not be applied.~~

~~*Paragraph 2.6.1., renumber the reference to and footnote 1/ to read footnote 2/.*~~